



### Test Method C-99-87 (2000)

#### Standard Test Methods for Determining the Modulus of Rupture of Dimension Stone

This test measures the modulus of rupture of all types of dimension stone, except slate.

The values stated in pounds per square inch are to be regarded as the standard.

This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

#### **Silestone® Results:**

Modulus of Rupture (C-99)

**6310 psi**