



Test Method C-97-96e1

Standard Test Methods for Determining the Absorption and Bulk Specific Gravity of Dimension Stone

This test measures the Absorption and Bulk Specific Gravity of any dimension stone, except slate.

The values stated in SI units are to be regarded as the standard.

This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

Silestone® Results:

Water Absorption (ASTM C-97)

0.03%